

Test Code Sheet Number	5	0	1	1	3
---------------------------------------	----------	----------	----------	----------	----------

WBS TEST & ACCEPTANCE CRITERIA
PD.JCS

Issue No: 2
Date of issue: January 1990

Sheet 1 of 1

TEST CODE SHEET

1. **TYPE OF TEST(S)**

Measurement of dimension.

2. **BYELAW REQUIREMENT FOR FITTINGS**

Byelaw 82

(1) Every urinal which is cleared by water after use shall be supplied with water from a flushing cistern or flushing trough which incorporates siphonic apparatus and is designed or adapted to supply no more water than is necessary.

3. **BRITISH STANDARDS OR WATER SPECIFICATION, DEEMED TO SATISFY BYELAW REQUIREMENTS**

(See Water Supply Byelaw Guide)

3.1 Fittings with 'kitemarks' which are deemed to satisfy the requirements of byelaws are listed in the directory.

4. **TEST PROCEDURE**

Note Unless stated otherwise the temperature of the test fluid shall be $20 \pm 10^{\circ}\text{C}$.

4.1 Tests applicable to the following fittings-

CISTERNS, URINAL FLUSHING
- automatic, all materials

(A) **AUTOMATIC URINAL FLUSHING CISTERNS**

TEST METHOD

Establish, by operational tests as necessary, the vertical distance between the spill-over level of the top of the cistern and the highest level that can be reached by the water in the cistern before siphonage commences.

5. **ACCEPTANCE CRITERIA**

The vertical distance established shall be not less than 25mm. The fitting shall also meet the acceptance criteria of TCS 3212.2.